

18

EU DECLARATION OF CONFORMITY

We,

Dwyer Instruments, Inc.
102 Indiana Highway 212
Michigan City, IN 46360 USA
+1-219-879-8868

declare under our sole responsibility our Series RHPLC Wall Mount Humidity/Temperature Transmitter to which this declaration relates is in conformity with the following EU Directives and harmonized Standards:

Directive 2011/65/EU Restriction of Certain Hazardous Substances in Electrical and Electronic Equipment + Directive (EU) 2015/863 Amendment to Annex II (RoHS)

Directive 2014/30/EU Electromagnetic Compatibility (EMC)

IEC 61326-1:2013 Electrical Equipment for Measurement, Control and Laboratory Use - EMC Requirements - Part 1: General Requirements

IEC 61000-4-2:2008 Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

IEC 61000-4-3:2006+A1:2008+A2:2010 Electromagnetic Compatibility (EMC) - Part 4-3: Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

IEC 61000-4-4:2012 Electromagnetic Compatibility (EMC) - Part 4-4: Testing and Measurement Techniques - Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-5:2014 Electromagnetic Compatibility (EMC) - Part 4-5: Testing and Measurement Techniques - Surge Immunity Test

IEC 61000-4-6:2013 Electromagnetic Compatibility (EMC) - Part 4-6: Testing and Measurement Techniques - Immunity to Conducted Disturbances, Induced By Radio-Frequency Fields

EN 55011:2016 Industrial, Scientific and Medical Equipment - Radio-Frequency Disturbance Characteristics - Limits and Methods of Measurement

The authorized representative located within the Community is:

Comhas Srl
Via Matteotti 66
200092 Cinisello Balsamo
Milano, Italy
+39 335.7064538

On behalf of Dwyer Instruments, Inc.,



Doug McCall
Senior Regulatory Engineer
July 31, 2021
Michigan City, Indiana, USA